

**UTILITIES COMMISSION**  
**City of New Smyrna Beach, Florida**  
**200 Canal Street**  
**P.O. Box 100**  
**New Smyrna Beach, Fl. 32170-010**

March 9, 2010

RE: RFQ 10-454A ADDENDUM **NO. 1**

To prospective bidders:

The Utilities Commission is issuing the following addendum. As such it becomes an integral part of the bid and must be acknowledged by the return of this signed form.

The following questions were asked and are answered below:

**1) Does the bid include removal and hauling of existing concrete?**

No, the Utilities Commission will have the concrete removed and hauled off. Vendor will be responsible for grading, framing, pouring and finishing.

**2) Who pulls the DOT permits?**

The Utilities Commission will pull the DOT permits and may also include concrete work in other pipe laying permits. Permitting for smaller jobs will be addressed on an as needed basis.

**3) Who does the inspection?**

Inspections will be performed in-house by Mr. Bill Dean or his designee

**4) Will there be a standard line for a minimum "Mobility Fee"?**

Please see below as we have added a line for such a fee.

**5) What is the concrete spec required?**

Concrete is to be 3000 PSI

**6) Do we need to install ADA mats?**

ADA mats are to be installed if replacing a section where required.

**7) Do the curbs need to be saw cut?**

Yes..

**8) Are expansion boards required?**

If existing area had them, everything needs to be returned to its original state. We will provide contractor with video footage of area prior to demolition.

**9) Fiber based concrete in Venetian bay?**

This will be spot quoted on an "as needed" basis

**10) Density testing & requirements?**

All projects will require density testing. Requirements are 96.2 modified.

**11) Materials cost (i.e. rebar/mesh)?**

Please see new tab sheet as we have added a line for such costs.

**12) Do we use Rebar or Wire Mesh.**

We will replace with whatever materials were in the previous construction.

**13) Escalation Clause?**

The Utilities Commission has a +/- clause that is used upon acceptance and renewal of annual contracts.

**UTILITIES COMMISSION**  
City of New Smyrna Beach  
RFQ No 10-454A

**QUOTE FORM**

<b><u>DESCRIPTION</u></b>	<b><u>UNIT PRICE</u></b>
<b><u>MATERIALS</u></b>	
Rebar (steel)	\$ _____
Rebar (Fiberglass)	\$ _____
Wire Mesh	\$ _____
ADA Matting	\$ _____
Minimum Mobilization Charge	\$ _____
Density Testing	\$ _____

The Utilities Commission reserves the right to waive informalities in any quotation, to reject any and all quotations in whole or in part, with or without cause, and/or accept the quotations or portions thereof that in its judgment will be in the best interest of the Utilities Commission. The quotation shall be valid for award within sixty (60) days from the date of opening unless specified otherwise.

**ACKNOWLEDGEMENT OF ADDENDUM NO 1**

**Company** \_\_\_\_\_

**Name & Title** \_\_\_\_\_

**Signature** \_\_\_\_\_