

UTILITIES COMMISSION

**City of New Smyrna Beach, Florida
200 Canal Street
P.O. Box 100
New Smyrna Beach, FL 32170-010**

November 29, 2016

RE: Bid No. 04-17 **ADDENDUM NO. 01**

1. Q: Section IV Enclosure A.1: The dimensions listed in the technical specifications of 88in. X 84in. appear to be that of a Type 10 and Type 11 switchgear. S&C Type 9 dimensions are 82in. X 84in., can you please confirm desired dimensions?

A: 82in. x 84in. is acceptable.

2. Q: Section IV Enclosure D.4: The technical specification requires for the door holders to hold the door open at angles of 90, 110, and 120 degrees. S&C Type 9 only allows for one position at approximately 110 degrees. Will this exception be acceptable?

A: 110 degrees is acceptable.

To prospective Bidders:

The Utilities Commission is issuing the following addendum. As such, it becomes an integral part of the Bid and must be acknowledged by the return of this signed form, with your Bid Form, acknowledging receipt of the addendum.

Acknowledgment of Receipt of ADDENDUM NO. 01

Company: _____

Name & Title: _____

Signature: _____