

UTILITIES COMMISSION

**City of New Smyrna Beach, Florida
200 Canal Street
P.O. Box 100
New Smyrna Beach, FL 32170-010**

May 16, 2017

RE: Bid No. 10-17 **ADDENDUM NO. 02**

Informational Comment:

Alternates to the specified material will be considered after award of the bid. Bids should be submitted using the specified materials. The UCNSB and its Consultant will consider alternatives and the alternative's potential cost savings to the UCSNB after award of bid.

Contractor Questions:

1. Can we use 0.040 color metal in place of the 5/8" plywood soffits and sheathing on details 1-6 A-503 as it will increase replacement time and not need the same maintenance as painted wood sheathing would in the future.

Response: Vertical plywood sheathing on perimeter stud walls is needed for structural support. Plywood soffits are currently only specified for three (3) of the small pump houses (Pump House 1, 5 and 6). There are no plywood soffits on the other pump houses. Bids should be based on the use of plywood soffits (refer to Informational Comment above).

To prospective Bidders:

The Utilities Commission is issuing the following addendum. As such, it becomes an integral part of the Bid and must be acknowledged by the return of this signed form, with your Bid Form, acknowledging receipt of the addendum.

Acknowledgment of Receipt of ADDENDUM NO. 02

Company: _____

Name & Title: _____

Signature: _____