

UTILITIES COMMISSION  
CITY OF NEW SMYRNA BEACH, FLORIDA  
200 CANAL STREET  
P.O. BOX 100  
NEW SMYRNA BEACH, FL 32170-010

ITB #02-21  
MISCELLANEOUS SEWER IMPROVEMENTS

DATE: November 24, 2020

RE: Bid No. 02-21 ADDENDUM NO. 01

To prospective vendors:

The Utilities Commission is issuing the following addendum. As such it becomes an integral part of the proposal and must be acknowledged by the return of this signed form, with your proposal form, acknowledging receipt of the addendum.

**VENDORS ARE ENCOURAGED NOT TO ATTEND  
BID OPENINGS IN PERSON BUT TO ATTEND BY  
DIALING 1 (646) 570-1040 PIN: 924-5593**

**THE UTILITIES COMMISSION, CITY OF NEW  
SMYRNA BEACH TAKES THIS STEP IN AN  
ABUNDANCE OF CAUTION FOR THE SAFETY  
AND WELLBEING OF OUR STAFF AND  
COMMUNITY.**

**IF YOU ARE DROPPING OFF A BID PLEASE  
RING THE BELL AND THE SECURITY GUARD  
WILL TAKE IT FROM YOU.**

**UTILITIES COMMISSION**  
CITY OF NEW SMYRNA BEACH, FLORIDA  
200 CANAL STREET  
P.O. BOX 100  
NEW SMYRNA BEACH, FL 32170-010

ITB #02-21  
MISCELLANEOUS SEWER IMPROVEMENTS

**Bidders shall note the following statements when preparing bids for evaluation:**

- See Revised Pages: 2, 32 & 33. Revisions are depicted in red.
- The **COMMISSION** has eliminated the two terminal manholes on Washington St. from the bid quantity. See revised Exhibit 01.
- The **COMMISSION** has added 330 LF of 6-Inch Lateral Liner (Bid Item 10). See Exhibit 07 added.
- Prior to asphalt patch, the soil densities shall be approved by the City of New Smyrna Beach Engineer. See Bid Item No. 28.
- Prior to start of work, survey stakes shall be installed in 50-foot increments (min.), to delineate the Right-of-Way/property lines along S. Riverside Dr. and the utility easement between 5<sup>th</sup> St. & 6<sup>th</sup> St. See Bid Item No. 29.
- There may be minimal underbrush & fence removal in the utility easement between 5<sup>th</sup> St. & 6<sup>th</sup> St. This work will fall under Project Contingency (Bid Item 27) and shall be approved by the **COMMISSION**.
  - The underbrush will not be replaced.
  - Should fencing be required to be removed, the same fence material shall be re-installed.
- The City of New Smyrna Beach will require this project and its impending traffic control requirements to go before their Commission. I anticipate January or February 2021.

**UTILITIES COMMISSION**  
CITY OF NEW SMYRNA BEACH, FLORIDA  
200 CANAL STREET  
P.O. BOX 100  
NEW SMYRNA BEACH, FL 32170-010

ITB #02-21  
MISCELLANEOUS SEWER IMPROVEMENTS

**BIDDER** questions are in black. **COMMISSION** responses are in blue.

1. Do you handle the soil testing or the GC? **The Contractor will be responsible for Geotech Soil Testing. See Revised Bid Tabulation, Bid Item No. 28.**
2. Item # 9 & 10 – in a previous bid this item was listed as “ Lateral Liner < 30 feet”, with a Unit of EA (each) Currently 9 & 10 are listed as a Unit of “LF” – can the City clarify?  
**The Utilities Commission, City of New Smyrna Beach is a separate entity than the City of New Smyrna Beach.**  
**Bid Item No. 9 is only for the laterals on S. Riverside Dr. The linear footage is an estimated accumulative since each lateral linear footage will vary since the existing gravity sanitary sewer main alignment is skewed. See construction plans.**

***A Copy of This Signed Form Must Accompany Your Proposal***

**Acknowledgment of Receipt of Addenda No. 1**

Company \_\_\_\_\_

Title \_\_\_\_\_

Signature \_\_\_\_\_