

UTILITIES COMMISSION

**City of New Smyrna Beach, Florida
200 Canal Street
P.O. Box 100
New Smyrna Beach, FL 32170-010**

December 26, 2017

RE: Bid No. 05-18 **ADDENDUM NO. 01**

Contractor Questions:

- 1) Please define what constitutes one operation of the required 10,000; pdf doc page 20 I.1.
on page 20 1.1 one mechanical operation is one trip and one reclose.
- 2) May an alternate quote for a single phase operable three phase recloser with SEL 651R relay be quoted as there would be significant reliability benefits to UCNSB's customers; pdf doc page 21 O.? **We use only three phase operations no single phase protection. the 651-R2 is very similar and can be used**
- 3) Per your instructions on subject RFQ we would like further clarification before submitting a proposal. Our recloser has two areas which do not meet your specifications. Para. L - Specified Housing-Stainless Steel. Our Housing is Aluminum. **The aluminum enclosure is good**
- 4) Para. O -Specified Control - Schweitzer SEL 351-R. Our control is Schweitzer SEL 651-R2. **the 651-R2 is very similar and can be used**

To prospective Bidders:

The Utilities Commission is issuing the following addendum. As such, it becomes an integral part of the Bid and must be acknowledged by the return of this signed form, with your Bid Form, acknowledging receipt of the addendum.

Acknowledgment of Receipt of ADDENDUM NO. 01

Company: _____

Name & Title: _____

Signature: _____