



# Florida Department of Environmental Protection

Central District  
3319 Maguire Boulevard, Suite 232  
Orlando, Florida 32803-3767

Rick Scott  
Governor

Carlos Lopez-Cantera  
Lt. Governor

Noah Valenstein  
Secretary

## NOTIFICATION OF ACCEPTANCE OF USE OF A GENERAL PERMIT

<b>PERMITTEE:</b> City of New Smyrna Beach, Utilities Commission 200 Canal Street New Smyrna Beach, FL 32168 Derek Wainscott, PE, Director of Engineering  Email: <a href="mailto:dwainscott@ucnsb.org">dwainscott@ucnsb.org</a>	<b>PERMIT NUMBER:</b> <b>ISSUE DATE:</b>  <b>EXPIRATION DATE:</b> <b>COUNTY:</b> <b>PROJECT NAME:</b>  <b>CONNECTED TO:</b> <b>FACILITY ID:</b>	0341884-004-DWC/CG December 14, 2017  December 13, 2022 Volusia NSB LS #11  New Smyrna Beach WRF FL0172090
--	---	--

Dear Mr. Wainscott:

This letter acknowledges receipt of your Notification/Application for Constructing a Domestic Wastewater Collection/Transmission System for the subject project. Our office received the Notice on December 13, 2017.

*This is to advise you that the Department does not object to your use of such General Permit.*

Please note the attached requirements apply to your use of this General Permit for constructing the proposed domestic wastewater collection/transmission system.

You are further advised that the construction activity must conform to the description contained in your Notification/Application for Constructing a Domestic Wastewater Collection/Transmission System and that any deviation will subject the permittee to enforcement action and possible penalties.

Sincerely,

A handwritten signature in cursive script that reads "Wanda Parker-Garvin".

Wanda Parker-Garvin  
Environmental Manager  
Permitting and Waste Cleanup Program - Wastewater

WPG/rc

cc: Dana Hale, PE, City of New Smyrna, [dhale@ucnsb.org](mailto:dhale@ucnsb.org)  
Charles LeGros, DEP, [Charles.LeGros@dep.state.fl.us](mailto:Charles.LeGros@dep.state.fl.us)  
Randall Cunningham, DEP, [Randall.Cunningham@dep.state.fl.us](mailto:Randall.Cunningham@dep.state.fl.us)

## REQUIREMENTS FOR USE OF THE GENERAL PERMIT FOR DOMESTIC WASTEWATER COLLECTION/TRANSMISSION SYSTEMS:

1. This general permit is subject to the general permit conditions of Rule 62-4.540, F.A.C., as applicable. This rule is available at the Department's Internet site at:  
<http://www.dep.state.fl.us/legal/Rules/shared/62-4/62-4.pdf> [62-4.540]
2. This general permit does not relieve the permittee of the responsibility for obtaining a dredge and fill permit where it is required. [62-604.600(6)(b)1]
3. This general permit cannot be revised, except to transfer the permit. [62-604.600(6)(b)2]
4. This general permit will expire five years from the date of issuance. If the project has been started and not completed by that time, a new permit must be obtained before the expiration date in order to continue work on the project. [62-4.030]
5. Upon completion of construction of the collection/transmission system project, and before placing the facilities into operation for any purpose other than testing for leaks or testing equipment operation, the permittee shall submit to the Department's Central District Office Form 62-604.300(8)(b), Request for Approval to Place a Domestic Wastewater Collection/Transmission System into Operation. This form is available at the Department's Internet site at: <http://www.dep.state.fl.us/water/wastewater/dom/dw-forms.htm>. [62-604.700(2)]

**Please submit the entire clearance document package in electronic format to [DEP\\_CD@dep.state.fl.us](mailto:DEP_CD@dep.state.fl.us), with a copy to [Randall.Cunningham@dep.state.fl.us](mailto:Randall.Cunningham@dep.state.fl.us), and [Charles.LeGros@dep.state.fl.us](mailto:Charles.LeGros@dep.state.fl.us).** If the file is very large, you may post it to the Wastewater Electronic Applications folder on the following ftp site at:

<ftp://ftp.dep.state.fl.us/pub/wastewater/>

After posting the document, send an e-mail to [DEP\\_CD@dep.state.fl.us](mailto:DEP_CD@dep.state.fl.us), with a copy to [Randall.Cunningham@dep.state.fl.us](mailto:Randall.Cunningham@dep.state.fl.us), and [Charles.LeGros@dep.state.fl.us](mailto:Charles.LeGros@dep.state.fl.us), alerting us that it has been posted. Any submitted drawings (should be sized 11" x 17") and the engineer of record's signed seal and dates on the required document must be legible for acceptance.

For further clarification contact:  
Randall Cunningham, (407) 897-4152  
3319 Maguire Blvd, Suite 232  
Orlando, Florida 32803-3767

6. The new or modified collection/transmission facilities shall not be placed into service until the Department clears the project for use. [62-604.700(3)]
7. Abnormal events shall be reported to the Department's Central District Office in accordance with Rule 62-604.550, F.A.C. For unauthorized spills of wastewater in excess of 1000 gallons per incident, or where information indicates that public health or the environment may be endangered, oral reports shall be provided to the STATE WATCH OFFICE TOLL FREE NUMBER (800)320-0519 as soon as practical, but no later than 24 hours from the time the permittee or other designee becomes aware of the circumstances. Unauthorized releases or spills less than 1000 gallons per incident are to be reported orally to the Department's Central District Office within 24 hours from the time the permittee, or other designee becomes aware of the circumstances. [62-604.550]