

UTILITIES COMMISSION
City of New Smyrna Beach, Florida
200 Canal Street
P.O. Box 100
New Smyrna Beach, Fl. 32170-010

February 6, 2019

RE: ITB 12-19 Three Phase Reclosers ADDENDUM **No. 1**

To prospective vendors:

The Utilities Commission is issuing the following addendum. **As such it becomes an integral part of the proposal and must be acknowledged by the return of this signed form, with your proposal form, acknowledging receipt of the addendum.**

The following questions have been asked and are answered below:

1. Please confirm that item one (3-PH Vac Recloser) is to be quoted without the 3-PH line side and load side arrestors. Correct, No Arresters are to be quoted with the Recloser or the Brackets.
2. What are the specs for the arrestors (both Line and Load side). UC will supply its own 18kV Arresters that we carry in our warehouse

A Copy of This Signed Form Must Accompany Your Proposal

Acknowledgment of Receipt of Addenda No. 1

Company_____

Title_____

Signature_____