

UTILITIES COMMISSION
City of New Smyrna Beach, Florida
200 Canal Street
P.O. Box 100
New Smyrna Beach, Fl. 32170-010

August 7, 2020

RE: ITB 26-20 South Beach Pumping Station Upgrades
ADDENDUM No. 2

To prospective vendors:

The Utilities Commission is issuing the following addendum. **As such it becomes an integral part of the proposal and must be acknowledged by the return of this signed form, with your proposal form, acknowledging receipt of the addendum.**

**VENDORS ARE ENCOURAGED NOT TO
ATTEND BID OPENINGS IN PERSON BUT TO
ATTEND BY DIALING 1 (646) 570-1040 PIN:
924-5593**

**THE UTILITIES COMMISSION, CITY OF
NEW SMYRNA BEACH TAKES THIS STEP IN
AN ABUNDANCE OF CAUTION FOR THE
SAFETY AND WELLBEING OF OUR STAFF
AND COMMUNITY.**

**IF YOU ARE DROPPING OFF A BID PLEASE
RING THE BELL AND THE SECURITY
GUARD WILL TAKE IT FROM YOU.**

UTILITIES COMMISSION
City of New Smyrna Beach, Florida
200 Canal Street
P.O. Box 100
New Smyrna Beach, Fl. 32170-010

Question 1: Is there an actual duty point / condition point for these pumps?

Response: *Duty point is: 1,000 gpm @ 68 psi.*

A Copy of This Signed Form Must Accompany Your Proposal

Acknowledgment of Receipt of Addenda No. 2

Company_____

Title_____

Signature_____