

UTILITIES COMMISSION
City of New Smyrna Beach, Florida
200 Canal Street
P.O. Box 100
New Smyrna Beach, Fl. 32170-010

July 14, 2020

RE: ITB 27-20 Sugar Mill Dr 20-inch reclaim Main Relocation
ADDENDUM No. 1

To prospective vendors:

The Utilities Commission is issuing the following addendum. **As such it becomes an integral part of the proposal and must be acknowledged by the return of this signed form, with your proposal form, acknowledging receipt of the addendum.**

**VENDORS ARE ENCOURAGED NOT TO
ATTEND BID OPENINGS IN PERSON BUT TO
ATTEND BY DIALING 1 (646) 570-1040 PIN:
924-5593**

**THE UTILITIES COMMISSION, CITY OF
NEW SMYRNA BEACH TAKES THIS STEP IN
AN ABUNDANCE OF CAUTION FOR THE
SAFETY AND WELLBEING OF OUR STAFF
AND COMMUNITY.**

**IF YOU ARE DROPPING OFF A BID PLEASE
RING THE BELL AND THE SECURITY
GUARD WILL TAKE IT FROM YOU.**

UTILITIES COMMISSION
City of New Smyrna Beach, Florida
200 Canal Street
P.O. Box 100
New Smyrna Beach, Fl. 32170-010

1. Is clearing/grubbing the responsibility of the contractor? If yes, will there be a bid line item added for that?

UCNSB Response: GeoSam has been tasked with the clearing and grubbing of the easement. In the event that UCNSB begins the construction before GeoSam has performed that task, or that additional clearing and grubbing is required, we have added an additional line item to the bid tab to accommodate clearing and grubbing in an “if necessary” basis.

2. There are conflicts on the drawings per sheet 16.1 (Conflict 3), will the proposed 24” RCP be installed before the Reclaim installation? If not, will the utility contractor install the reclaim main per plans to account for future conflict?

UCNSB Response: It is unlikely that the 24” RCP will be installed in advance of the reclaim main construction. Yes, the utility contractor will perform the reclaim main conflict deflections per the plan in order to allow for the storm system construction in the future.

A Copy of This Signed Form Must Accompany Your Proposal

Acknowledgment of Receipt of Addenda No. 1

Company_____

Title_____

Signature_____

**UTILITIES COMMISSION
CITY OF NEW SMYRNA BEACH, FLORIDA**

ITB #27-20
SUGAR MILL DRIVE 20-INCH RECLAIMED MAIN RELOCATION

**BID TABULATION
page 1 of 2**

BIDDER NAME: _____

| Item No. | Description | Est. Quantity | Unit | Unit Price | Total |
|-----------------|---|----------------------|-------------|-------------------|--------------|
| 1 | Mobilization/Demobilization | 1 | LS | \$ | \$ |
| 2 | Maintenance of Traffic | 1 | LS | \$ | \$ |
| 3 | As-Built/Survey | 1 | LS | \$ | \$ |
| 4 | Dewatering | 1 | LS | \$ | \$ |
| 5 | Removal of unsuitable soils within pipe trench and replacement with suitable material | 1,500 | CY | \$ | \$ |
| 6 | Installation of 20-inch Reclaimed Main including all valves and appurtenances | 1 | LS | \$ | \$ |
| 7 | Installation of 20-inch Line Stop Valves (if necessary) | 2 | EA | \$ | \$ |
| 8 | Abandonment/Grout fill of existing 20-inch Reclaimed Main | 1 | LS | \$ | \$ |
| 9 | Roadway Restoration | 1 | LS | \$ | \$ |
| 10 | Project Contingency | 1 | LS | \$ 20,000.00 | \$ 20,000.00 |
| 11 | Clearing and Grubbing (if necessary) | 1 | AC | \$ | \$ |

TOTAL NUMERIC BID COST \$ _____

TOTAL WRITTEN BID COST: _____

